



Type Approval Certificate Extension

This is to certify that Certificate No. 98/60058(E2) for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER	General Cable Industries, Inc.												
PLACE OF PRODUCTION	1600 West Main Street Willimantic CT 06226-1228 USA												
DESCRIPTION	Power cable - Single conductor; cross linked polyolefin, irradiated insulation (Type P); optional armour with modified chlorosulphonated polyethylene sheath (Type CP)												
TYPES	Polyrad XT												
APPLICATION	Marine, offshore and industrial.												
SPECIFIED STANDARD	IEEE45: 1998 IEC60332-3 (Category A) IEEE1580:2001												
TECHNICAL DETAILS	<table><thead><tr><th></th><th colspan="2"><u>Conductor size (mm²)</u></th></tr></thead><tbody><tr><td>Single conductor armoured:</td><td>8.4 to 563.1</td><td>(8AWG to 1111MCM)</td></tr><tr><td>Single conductor unarmoured:</td><td>107.2 to 563.1</td><td>(4/0AWG to 1111MCM)</td></tr><tr><td>Marine bronze armoured and sheathed:</td><td>8.4 to 563.1</td><td>(8AWG to 1111MCM)</td></tr></tbody></table> <p>Rated voltage: 2000V Maximum conductor temperature: 100°C</p>		<u>Conductor size (mm²)</u>		Single conductor armoured:	8.4 to 563.1	(8AWG to 1111MCM)	Single conductor unarmoured:	107.2 to 563.1	(4/0AWG to 1111MCM)	Marine bronze armoured and sheathed:	8.4 to 563.1	(8AWG to 1111MCM)
	<u>Conductor size (mm²)</u>												
Single conductor armoured:	8.4 to 563.1	(8AWG to 1111MCM)											
Single conductor unarmoured:	107.2 to 563.1	(4/0AWG to 1111MCM)											
Marine bronze armoured and sheathed:	8.4 to 563.1	(8AWG to 1111MCM)											

Certificate No.	98/60058(E3)
Issue Date	2 September 2008
Expiry Date	21 April 2013
Sheet	1 of 2


F.P.D.E. Taylor



Lloyd's Register North America, Inc.
1000, South Pine Island Road, Suite #530, Plantation, Florida, 33324, USA

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.




"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No. 98/60058(E3) and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as previous Certificate No. 98/60058(E2) to which this extension should be attached.

Certificate No. 98/60058(E3)
Issue Date 2 September 2008
Expiry Date 21 April 2013
Sheet 2 of 2


D.E. Taylor



Lloyd's Register North America, Inc.
1000, South Pine Island Road, Suite #530, Plantation, Florida, 33324, USA

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Marine Design Appraisal Document

Lloyd's Register North America, Inc.
Miami Design Support Office
1000 South Pine Island Road
Suite 530
Plantation
Florida 33324, USA

Date
02 September 2008

Quote this reference on all future communications
MDSO/DET/O-8620

LLOYD'S REGISTER TYPE APPROVAL SYSTEM 2002
Issued to: GENERAL CABLE INDUSTRIES, INC.
For: POLYRAD XT CABLE
TYPE APPROVAL CERTIFICATE NO: 98/60058(E3)

The undernoted documents have been reviewed for compliance with the requirements of Lloyd's Register's Type Approval System, 2002 and this Design Appraisal Document is a supplement to the Certificate.

APPROVAL DOCUMENTATION

Approval Services Request for Quotation – LR 6606NA
MMI0843032 – Inspection and Surveillance of Production Facilities Report

30 April 2008
7 August 2008

Supplementary Type Approval Terms and Conditions

Type Approval certifies that a representative sample of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein. It does not mean or imply approval for any other use, nor approval of any product(s) designed or manufactured otherwise than in strict conformity with the said representative sample.

Type Approval is based on the understanding that the manufacturer's recommendations and instructions and any relevant requirements of the Rules and Regulations are complied with.

Type Approval does not eliminate the need for normal inspection and survey procedures required by the Rules and Regulations.

Lloyd's Register North America, Inc. reserves the right to cancel or withdraw this Type Approval Certificate in accordance with the Lloyd's Register Type Approval System Procedure.


D.E. Taylor
Senior Surveyor
Lloyd's Register North America Inc.
Miami Design Support Office
Tel (1) 954 236 3322
Fax (1) 954 452 3128
davide.taylor@lr.org

FINAL ACCEPTANCE OF ACTUAL ITEM(S) DEPEND(S) ON SATISFACTORY SURVEY AND TESTING

Lloyd's Register North America, Inc.
is a member of the Lloyd's Register Group

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Part 1B
Subject: Electrical Equipment (Not Environmentally Tested)
Product: Cables Power (Part 1B)

Producer/Licence No.		Description of Product			Cert. No.
Type	Details of Approval	Application	Remarks		
General Cable Industries, Inc. 1600 West Main Street Willimantic CT 06226-1228 USA	Polyrad XT Single conductor; cross linked polyolefin, irradiated insulation (Type P); optional armour with modified chlorosulphonated polyethylene sheath (Type CP) Single conductor armoured: Conductor size (mm ²) 8.4 to 563.1 (8AWG to 1111MCM) Single conductor unarmoured: 107.2 to 563.1 (4/0AWG to 1111MCM) Marine bronze armoured and sheathed: 8.4 to 563.1 (8AWG to 1111MCM) Rated voltage: 2000V Maximum conductor temperature: 100°C	General power, lighting and control for marine, offshore and industrial use.	Expires: 21 April 2013 IEEE45: 1998 IEC60332-3 (Category A) IEEE1580:2001	98/60058(E3)	

