



Alben Roland
Engineering Manager - Carol® Brand Electronics Products

January 30, 2009

Dear Concerned Customer:

I have received an inquiry regarding installation of General Cable's Carol® brand plenum rated products that may have been exposed to sub-freezing temperatures while stored at a construction site. All of these products are suitable for use from 0°C to +60°C. Before installing the cables, leave them undisturbed and raise the temperature of the surrounding environment to above 0°C for a minimum of four hours in order to avoid damage during installation. The cable should be pulled immediately upon exposure to the sub-freezing temperatures.

Sincerely,
Alben Roland

Alben Roland

345 McGregor Drive
Manchester, NH 03102
tel: 603.792.4219
fax: 603.622.3164
e-mail: info@generalcable.com
web: www.generalcable.com