



# Certificate of Compliance

**Certificate:** 1408070 (LL 7319)

**Master Contract:** 156400

**Project:** 2415007

**Date Issued:** May 5, 2011

**Issued to:** General Cable Industries, Inc.

1600 West Main St  
Willimantic, CT 06226-1128  
USA  
Attention: Jeff Schroeder

*The products listed below are eligible to bear the CSA Mark shown*



*Kim Nguyen*

**Issued by:** Kim Nguyen, P. Eng.

## **PRODUCTS**

**CLASS 5812 01** - CABLE - Metal Sheathed

**CLASS 5818 02** - CABLE - Metal Sheathed - For Hazardous Locations

Type RA90, HL, 600V, 1000V, 5000V, FT4, AG14, -40C, SR, single conductor

Type RA90, HL, 600V, 1000V, FT4, AG14, -40C, SR, multiple conductors

Type RA90, HL, 5000V, FT4, AG14, -40C, SR, multiple conductors

Type RA90, 600V, 1000V, 5000V, FT4, -40C, SR, single conductor

Type RA90, 600V, 1000V, FT4, -40C, SR, multiple conductors

Type RA90, 5000V, FT4, -40C, SR, multiple conductors

## **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 123 – Metal Sheathed Cables

CSA C22.2 No. 174 – Cables and Cable Glands for Use in Hazardous Locations